

Lead in Drinking Water Analytical Results Summary
 Utica Academy of Science Elementary School
 160 School Lane, Frankfort, New York

School / Sample Identification #	Date/Time Collected	Sample Location	Total Lead (ug/L)
UAS-ES-1	4/24/2025 08:22	Staff restroom sink next 158 (left)	<1.0
UAS-ES-2	4/24/2025 08:23	Staff restroom sink next 158 (right)	3.2
UAS-ES-3	4/24/2025 08:37	164- Classroom Sink	1.5
UAS-ES-4	4/24/2025 08:38	163- Classroom Sink	2.1
UAS-ES-5	4/24/2025 08:40	Drinking fountain next 164	<1.0
UAS-ES-6	4/24/2025 08:41	Bottle fountain next 164	<1.0
UAS-ES-7	4/24/2025 08:43	162- Classroom Sink	1.6
UAS-ES-8	4/24/2025 08:44	161- Classroom Sink	1.2
UAS-ES-9	4/24/2025 08:45	160- Classroom Sink	3.1
UAS-ES-10	4/24/2025 08:46	159- Classroom Sink	1.4
UAS-ES-11	4/24/2025 08:52	Drinking fountain next 159	<1.0
UAS-ES-12	4/24/2025 08:53	Bottle fountain next 159	<1.0
UAS-ES-13	4/24/2025 09:00	158 - Restrooom sink	39.2
UAS-ES-14	4/24/2025 09:01	158 - classroom sink	19.0
UAS-ES-15	4/24/2025 09:02	157- Classroom Sink	4.3
UAS-ES-16	4/24/2025 09:03	155- Classroom Sink	1.2
UAS-ES-17	4/24/2025 09:06	101- Classroom Sink	13.0
UAS-ES-18	4/24/2025 09:07	102- Classroom Sink	10.2
UAS-ES-19	4/24/2025 09:08	103- Classroom Sink	76.8
UAS-ES-20	4/24/2025 09:09	104- Classroom Sink	7.1
UAS-ES-21	4/24/2025 09:10	Drinking fountain next 104	<1.0
UAS-ES-22	4/24/2025 09:11	Bottle fountain next 104	<1.0
UAS-ES-23	4/24/2025 09:20	105- Classroom Sink	44.4
UAS-ES-24	4/24/2025 09:21	106- Classroom Sink	34.5
UAS-ES-25	4/24/2025 09:22	107- Classroom Sink	15.6
UAS-ES-26	4/24/2025 09:23	108- Classroom Sink	4.9
UAS-ES-27	4/24/2025 09:25	109- Classroom Sink	26.5
UAS-ES-28	4/24/2025 09:26	110- Classroom Sink	4.9
UAS-ES-29	4/24/2025 09:28	Women's restroom sink nect to 109 (left)	6.6
UAS-ES-30	4/24/2025 09:29	Women's restroom sink nect to 109 (left-middle)	4.1
UAS-ES-31	4/24/2025 09:30	Women's restroom sink nect to 109 (right-middle)	4.0
UAS-ES-32	4/24/2025 09:31	Women's restroom sink nect to 109 (right)	4.8
UAS-ES-33	4/24/2025 09:32	Drinking fountain next 111	<1.0
UAS-ES-34	4/24/2025 09:33	Bottle fountain next 111	<1.0
UAS-ES-35	4/24/2025 09:37	Men's restroom sink nect to 113 (left)	2.0
UAS-ES-36	4/24/2025 09:38	Men's restroom sink nect to 113 (left-middle)	2.8
UAS-ES-37	4/24/2025 09:39	Men's restroom sink nect to 113 (right-middle)	42.2
UAS-ES-38	4/24/2025 09:40	Men's restroom sink nect to 113 (right)	5.6
UAS-ES-39	4/24/2025 09:44	117 -Women's Restroom sink	2.5
UAS-ES-40	4/24/2025 09:45	119 - Men's restroom sink	2.5
UAS-ES-41	4/24/2025 09:49	Art 116 - Restroom sink	<1.0
UAS-ES-42	4/24/2025 09:51	Art 116 - Classrom sink (left)	1.0
UAS-ES-43	4/24/2025 09:52	Art 116 - Classrom sink (right)	<1.0
UAS-ES-44	4/24/2025 09:53	Art 116 - Drinking fountain	<1.0
UAS-ES-45	4/24/2025 09:55	Nurse 120 - restroom sink	2.2
UAS-ES-46	4/24/2025 09:56	Nurse 120 - exam room sink	10.5
UAS-ES-47	4/24/2025 09:58	Drinking fountain next 123 (right)	<1.0
UAS-ES-48	4/24/2025 09:59	Drinking fountain next 123 (left)	<1.0
UAS-ES-49	4/24/2025 10:00	Bottle fountain next 123	<1.0
UAS-ES-50	4/24/2025 10:05	124 - Dean restroom sink	1.7
UAS-ES-51	4/24/2025 10:06	128 - Maintenance restroom sink	1.1
UAS-ES-52	4/24/2025 10:08	Cafeteria - Drinking fountain	<1.0
UAS-ES-53	4/24/2025 10:09	Cafeteria - Bottle fountain	<1.0
UAS-ES-54	4/24/2025 10:16	Kitchen - handwash sink near serving line	74.6
UAS-ES-55	4/24/2025 10:17	Kitchen - 2 bay near window	<1.0
UAS-ES-56	4/24/2025 10:18	Kitchen - dishwash sprayer	<1.0
UAS-ES-57	4/24/2025 10:19	Kitchen - 2 bay with chemical dispenser	3.6
UAS-ES-58	4/24/2025 10:20	Kitchen - 1 bay sink	8.9
UAS-ES-59	4/24/2025 10:21	Kitchen - hand wash	6.3
UAS-ES-60	4/24/2025 10:22	Kitchen - restoom sink	6.4
UAS-ES-61	4/24/2025 10:29	Drinking fountain next gym/cafeteria	<1.0
UAS-ES-62	4/24/2025 10:30	Bottle fountain next gym/cafeteria	<1.0
UAS-ES-63	4/24/2025 10:32	Boy's locker room sink	3.6
UAS-ES-64	4/24/2025 10:33	Girl's locker room sink	4.9

Notes:

Exceedances of New York Department of Health (NYSDOH) Action Level for Lead In School Drinking Water (5 ppb) are highlighted.

ug/L - micrograms per liter or part per billion (ppb)